



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 9/22/09

Code 53.31-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title P3105.1 Table, Maximum distance of fixture trap from vent		Page 1 of 2
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		

☐ Change to read as follows ☒ Add to read as follows ☐ Delete and substitute as follows ☐ Delete without substitution

TABLE P3105.1
MAXIMUM DISTANCE OF FIXTURE TRAP FROM VENT a.

SIZE OF TRAP (inches)	SLOPE (inch per foot)	DISTANCE FROM TRAP (feet)
1 $\frac{1}{4}$	$\frac{1}{4}$	5
1 $\frac{1}{2}$	$\frac{1}{4}$	6
2	$\frac{1}{4}$	8
3	$\frac{1}{8}$	12
4	$\frac{1}{8}$	16

a. A trap arm serving only a bath tub, tub/shower combination or shower may be increased to 9 feet (2743 mm) with a slope of not less than $\frac{1}{8}$ inch (3.175 mm) per foot.

For SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm,
1 inch per foot = 83.3 mm/m.

REASON

Brings forward current code amendment allowing a longer trap arm for these fixtures.

Fiscal impact: no increase to the cost of construction, current amendment language.

REVIEW RECOMMENDATION
Approve
Disapprove
Approve as amended
Further Study